



# Compliance Statement

## Screened Category 6 ISO/IEC, EN & TIA/EIA Connecting Hardware

### Fibrain Data Identification P/N XQ100.250

Category 6, Screened, Patch Panel  
Electrical Transmission Performance

**FIBRAIN Sp. z o.o.**  
**ul. Wspolna 4a,**  
**35-205 Rzeszow, Poland**

#### *Compliance Statement No. 110490C*

*This Screened ISO/IEC, EN & TIA Connecting Hardware having board identification "Cat.6 R001-0886 C6", has been tested by 3P Third Party Testing and complies with the Category 6 transmission requirements of edition 2.2 of ISO/IEC 11801, CENELEC EN 50173-1:2011, ANSI/TIA 568-C.2 and 2<sup>nd</sup> Edition IEC 60603-7-5. The requirements are passed using the total range of re-embedded vectors specified in ANSI/TIA-568-C.2 and draft IEC 60512-27-100. The qualification activity includes factory and assembly line inspection. The Compliance Statement may be suspended or withdrawn if the keystone jack fails to pass a Maintenance Testing performed at 12 month intervals.*

Hoersholm, 25<sup>th</sup> October 2011

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 25<sup>th</sup> October 2011

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien  
Coordinating Manager