



# Compliance Statement

## ISO/IEC, EN & TIA Screened Class E / Category 6 Two Connector Channel

**Fibrain Sp. z o.o.**  
**ul. Wspólna 4a**  
**35-205 Rzeszów, Poland**

**Compliance Statement No. 114896**

*This type of Class E / Category 6 screened two connector channel has been tested by 3P Third Party Testing and complies with the Class E requirements of Edition 2.2 of ISO/IEC 11801 and CENELEC EN 50173-1:2011, and Category 6 requirements of ANSI/TIA-568-C.2. The Compliance Statement is valid for the channel type in T568B designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 24 month intervals. The channel consists of the following Fibrain components:*

<i>Cables:</i>	<i>Horizontal Cables,</i>	<i>FibrainDATA Quick Series cables, P/N XQ100y1x6 (1x7), where "y" is "." for LSZH sheath or "F" for FR-LSZH sheath and "x" is "2" for U/FTP screening, "3" for F/FTP screening or "4" for S/FTP screening</i>
	<i>Flexible Cable,</i>	<i>from cords, P/N XQPxxx.412ppcbi</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jack,</i>	<i>P/N XQ100.450 and P/N XQ100.451 having PCB marking 001-9081</i>
	<i>Patch Panels:</i>	<i>P/N XQ100.250 and P/N XQ100.255 having PCB marking 001-0860</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Cords:</i>	<i>2,0 m - 5,0 m Patch Cords,</i>	<i>P/N XQPxxx.412ppcbi</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 12<sup>th</sup> December 2014

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 12<sup>th</sup> December 2014

*Poul Villien*

Poul Villien  
Coordinating Manager