



Compliance Statement

ISO/IEC, EN & TIA Screened Class E / Category 6 Two Connector Permanent Link

Fibrain Sp. z o.o.
ul. Wspólna 4a
35-205 Rzeszów, Poland

Compliance Statement No. 114868A

This type of Class E / Category 6 screened two connector permanent link has been tested by 3P Third Party Testing and complies with the Class E requirements of Edition 2.2 of ISO/IEC 11801 and CENELEC EN 50173-1:2011, and Category 6 requirements of ANSI/TIA-568-C.2. The Compliance Statement is valid for the permanent link type in T568B designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 24 month intervals. The permanent link consists of the following components, and when connected with RJ 45 plugs from Fibrain cords, P/N XQPxxx.412ppcbi:

<i>Cables:</i>	<i>Horizontal Cables,</i>	<i>FibrainDATA Quick Series cables, P/N XQ100y1x6 (1x7), where "y" is "." for LSZH sheath or "F" for FR-LSZH sheath and "x" is "2" for U/FTP screening, "3" for F/FTP screening or "4" for S/FTP screening</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jacks,</i>	<i>P/N XQ100.450 and P/N XQ100.451 having PCB marking 001-9081</i>
	<i>Patch Panels:</i>	<i>P/N XQ100.250 and P/N XQ100.255 having PCB marking 001-0860</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 24th September 2014

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 24th September 2014

Paul Villien

Poul Villien
Coordinating Manager