



Compliance Statement

ISO/IEC, EN & TIA Screened Class E_A / Category 6A Four Connector Channel


Fibrain Sp. z o.o.
ul. Wspólna 4a
35-205 Rzeszów, Poland

Compliance Statement No. 115923A


This type of Class E_A / Category 6A screened four connector channel has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E_A requirements of Edition 2.2 of ISO/IEC 11801 and CENELEC EN 50173-1:2011, and Category 6A requirements of ANSI/TIA-568-C.2. The Compliance Statement is valid for the channel type in T568B designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 24 month intervals. The channel consists of the following Fibrain components:

<i>Cables:</i>	<i>Horizontal Cable, Flexible Cable, Qualification Status:</i>	<i>FibrainDATA Rapid Series cables, P/N XR100.116 (117) from cords P/N XRPxxx.412ppcbis Manufacturer Verified</i>
<i>Conn. Hardware:</i>	<i>Keystone Jack, Patch Panels, Qualification Status:</i>	<i>P/N XR100.450 and P/N XR100.451 having PCB marking 001-9081 P/N XR100.250 and P/N XR100.255 having PCB marking 001-0860 Manufacturer Verified</i>
<i>Cords:</i>	<i>3,0 m - 5,0 m Consolidation Cords, 2,0 m - 5,0 m Patch Cords, Qualification Status:</i>	<i>Type FibrainDATA consolidation cords P/N XRPxxx.412ppcbis Manufacturer Verified</i>

Hoersholm, 19th February 2015


Ole Lambertsen
Test Responsible

Hoersholm, 19th February 2015


Poul Villien
Coordinating Manager