



Compliance Statement

Screened Category 6 ISO/IEC, EN & TIA/EIA Connecting Hardware

Fibrain Data Identification P/N XQ100.255

**Category 6, Screened, Patch Panel
Electrical Transmission Performance**

**FIBRAIN Sp. z o.o.
ul. Wspolna 4a,
35-205 Rzeszow, Poland**

Compliance Statement No. 111671

This Screened ISO/IEC, EN & TIA Connecting Hardware having board identification "Cat.6 R001-0886 C6", has been tested by 3P Third Party Testing and complies with the Category 6 transmission requirements of edition 2.2 of ISO/IEC 11801, CENELEC EN 50173-1:2011, ANSI/TIA 568-C.2 and 2nd Edition IEC 60603-7-5. The requirements are passed using the total range of re-embedded vectors specified in ANSI/TIA-568-C.2 and draft IEC 60512-27-100. The qualification activity includes factory and assembly line inspection. The Compliance Statement may be suspended or withdrawn if the keystone jack fails to pass a Maintenance Testing performed at 12 month intervals.

Hoersholm, 25th October 2011

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 25th October 2011

Poul Villien

Poul Villien
Coordinating Manager